

The website will be out of service for system upgrading and maintenance from February 19, 2014 to February 21, 2014. We apologize for any inconvenience this may cause.

[Sign In](#) | [Sign Up Now](#) | [Disclaimer](#) | [LegalZone Websites](#) | [Florida Websites](#)

• Boca Raton, Florida

BOCA RATON REGULATIONS^{ALPHA}

[Home](#) [Code](#) [Search](#) [Help](#)

 [Code of Ordinances](#)

■ [Part II. CODE OF ORDINANCES](#)

■ [Chapter 7. FIRE PREVENTION AND PROTECTION](#)

■ [Article IV. FIRE PROTECTION SYSTEMS](#)

■ [Section 7-82. Backflow prevention for fire protection systems](#)

[All Versions](#) [Related Contents](#)

Section 7-82. Backflow prevention for fire protection systems

Effective: Saturday, December 21, 2013

An approved double check valve assembly shall be installed on all fire mains serving all structures, except single-family homes and duplexes, as provided in NFPA 13 and NFPA 13R. An approved dual check valve assembly shall be installed on all fire mains serving single-family homes and duplexes (NFPA 13D).

(Ord. No. 5186, § 2, 12-13-11)