

The website will be out of service for system upgrading and maintenance from February 19, 2014 to February 21, 2014. We apologize for any inconvenience this may cause.

[Sign In](#) | [Sign Up Now](#) | [Disclaimer](#) | [LegalZone Websites](#) | [Florida Websites](#)

• Boca Raton, Florida

BOCA RATON REGULATIONS^{ALPHA}

[Home](#) [Code](#) [Search](#) [Help](#)

 [Code of Ordinances](#)

■ [Part II. CODE OF ORDINANCES](#)

■ [Chapter 7. FIRE PREVENTION AND PROTECTION](#)

■ [Article IV. FIRE PROTECTION SYSTEMS](#)

■ [Section 7-83. Fire mains](#)

[All Versions](#) [Related Contents](#)

Section 7-83. Fire mains

Effective: Saturday, December 21, 2013

Fire main taps connected to the public water system shall be sized for, and serve, only the building for which they were installed. Fire main taps shall not be shared with other buildings. Fire mains shall be constructed of class 52 ductile iron pipe (DIP) or other pipe UL listed for underground fire main use, as approved by the fire department. Fire main taps may be shared only where a single fire pump is shared in accordance with [section 7-84](#).

(Ord. No. 5186, § 2, 12-13-11)